



3300 Port 1

| Parameter | |
|--------------------------------|---|
| Baud Rate: | <input type="text" value="9600"/> bps(600~230400)bps |
| Data Size: | <input type="text" value="8"/> bit |
| Parity: | <input type="text" value="None"/> |
| Stop Bits: | <input type="text" value="1"/> bit |
| Serial Mode: | <input type="text" value="RS232"/> |
| Run Serial Mode: | <input type="text" value="RS232"/> |
| Flow Mode: | <input type="text" value="NONE"/> |
| UART Packet Time: | <input type="text" value="0"/> (0~255)ms |
| UART Packet Length: | <input type="text" value="0"/> (0~1460)chars |
| Sync Baudrate(RF2217 Similar): | <input checked="" type="checkbox"/> |
| Enable Uart Heartbeat Packet: | <input type="checkbox"/> |
| Socket A Parameters | |
| Work Mode: | <input type="text" value="TCP Client"/> <input type="text" value="None"/> |
| Remote Server Addr: | <input type="text" value="192.168.1.2"/> [192.168.1.2] |
| Local/Remote Port Number: | <input type="text" value="28"/> <input type="text" value="15374"/> (1~65535) |
| Timeout Reconnection : | <input type="text" value="1"/> (1~99999)s |
| PRINT: | <input type="checkbox"/> |
| ModbusTCP Poll: | <input type="checkbox"/> Poll Timeout : <input type="text" value="200"/> (200~9999) ms |
| Enable Net Heartbeat Packet: | <input type="checkbox"/> |
| parameter | |
| IP Type: | <input type="text" value="Static IP"/> |
| Static IP: | <input type="text" value="192"/> . <input type="text" value="168"/> . <input type="text" value="1"/> . <input type="text" value="7"/> |
| Submask: | <input type="text" value="255"/> . <input type="text" value="255"/> . <input type="text" value="255"/> . <input type="text" value="0"/> |
| Gateway: | <input type="text" value="192"/> . <input type="text" value="168"/> . <input type="text" value="1"/> . <input type="text" value="1"/> |
| Dns Server: | <input type="text" value="8"/> . <input type="text" value="8"/> . <input type="text" value="8"/> . <input type="text" value="8"/> |

Port 2

| Parameter | |
|--------------------------------|--|
| Baud Rate: | <input type="text" value="1200"/> bps(600~230400)bps |
| Data Size: | <input type="text" value="7"/> bit |
| Parity: | <input type="text" value="Even"/> |
| Stop Bits: | <input type="text" value="1"/> bit |
| Serial Mode: | <input type="text" value="RS232"/> |
| Run Serial Mode: | <input type="text" value="RS232"/> |
| Flow Mode: | <input type="text" value="NONE"/> |
| UART Packet Time: | <input type="text" value="0"/> (0~255)ms |
| UART Packet Length: | <input type="text" value="0"/> (0~1460)chars |
| Sync Baudrate(RF2217 Similar): | <input checked="" type="checkbox"/> |
| Enable Uart Heartbeat Packet: | <input type="checkbox"/> |
| Socket A Parameters | |
| Work Mode: | <input type="text" value="TCP Client"/> <input type="text" value="None"/> |
| Remote Server Addr: | <input type="text" value="192.168.1.2"/> [192.168.1.2] |
| Local/Remote Port Number: | <input type="text" value="26"/> <input type="text" value="6830"/> (1~65535) |
| Timeout Reconnection : | <input type="text" value="1"/> (1~99999)s |
| PRINT: | <input type="checkbox"/> |
| ModbusTCP Poll: | <input type="checkbox"/> Poll Timeout : <input type="text" value="200"/> (200~9999) ms |
| Enable Net Heartbeat Packet: | <input type="checkbox"/> |

192.168.1.7
admin/admin